

Informationen

zur Zertifizierung des Schallabsorbtionsgrads nach DIN EN ISO 354

Stoff • odense

Farb.-Nr. 625.xxL

Zertifikat-Nummer **21-000132-01**

Bestätigung Die Firma erfal bestätigt, dass dieser Qualität das Zertifikat **21-000132-01** zugrunde liegt.

Datum 26.02.2024



Jörg Erler
Geschäftsführer



Markus Milde
Geschäftsführer

erfal steht für Qualität Made in Germany.

Um eine lange Lebensdauer unter Wahrung der ursprünglichen Produkteigenschaften zu gewährleisten, sollten Sie die mitgelieferten Pflege- und Reinigungsmöglichkeiten unbedingt beachten.

Bei Fragen zur Pflege unserer Stoffe melden Sie sich bitte bei:

erfal GmbH & Co. KG
Gewerbering 8
D - 08223 Falkenstein

Fon +49 (0) 3745 750 0
Fax +49 (0) 3745 750 299
info@erfal.de

TFI Report 21-000132-01

Sound Absorption

Customer



Product

fabric



This report includes 2 pages and 1 annex



Responsible at TFI

Florian Guttenbacher, M.Sc.

- Test Engineer -

Tel: +49 241 9679 171

f.guttenbacher@tfi-aachen.de



Aachen, 19.02.2021

Dr.-Ing. Andreas Zoëga

- Head of the testing laboratory -



The present document is provided with an advanced electronic signature.

This report only applies to the tested samples and has been established to the best of our knowledge. Only the entire report shall be reproduced. Under no circumstances, extracts shall be used. Furthermore, we apply the "General Terms and Conditions for the Execution of Contracts" of the TFI Aachen GmbH, also with regard to the order execution.

1 Transaction

Test order	sound absorption according to EN ISO 354
Order date	29.01.2021
Your reference	Tanja Kraayenhof
Sampling performed by	Customer
Product designation	██████████
TFI sample number	2100195

2 Product Specification

Type of manufacture	woven
Type of surface	woven structure
Pattern	plain without pattern
Colour	dark blue
Thickness [mm]	0.51*
Area density [g/m ²]	208*
View	

*customer information

3 Results

Sound absorption	$\alpha_w = 0,55$ (H)
------------------	-----------------------

The measurement results are evaluated without consideration of the measurement uncertainty with reference to compliance with limit values, unless otherwise specified by the test standard.

4 Annexes

Sound absorption	SA 21-000132-01 ^a
------------------	------------------------------

The annexes marked ^a are based on tests accredited in accordance with EN ISO/IEC 17025.

Annex SA – Sound Absorption


1 Test Method / Requirements

EN ISO 354:2003-12	Acoustics - Measurement of sound absorption in a reverberation room
EN ISO 11654:1997-07	Acoustics - Sound absorbers for use in buildings - Rating of sound absorption
ISO 12999-2:2020-06	Acoustics - Determination and application of measurement uncertainties in building acoustics - Part 2: Sound absorption

2 Laboratories

Test rooms:	TFI Aachen GmbH, Charlottenburger Allee 41, 52068 Aachen
Test method:	reverberation room method
Volume:	$V = 7,60 \text{ m} \times 5,91 \text{ m} \times 4,95 \text{ m} = 222,33 \text{ m}^3$
Total surface:	$S_t = 223,60 \text{ m}^2$
Floor plan:	rectangular
Diffusors:	15

Plan of the reverberation room:



3 Measuring Devices

Real-time analyzer:	1 Norsonic Nor140
Microphone:	1 Norsonic Type1209
Loudspeaker:	2 Norsonic Nor229

4 Measuring Operation

Test noise:	broadband noise
Receive filter:	one-third octave band filter
Measurement:	2 loudspeaker positions 6 microphone positions

5 Evaluation

The decay curves are determined using the interrupted noise method. A minimum of one decay curve is measured at each of the 6 microphone positions. The decays are averaged for every microphone position to enhance reproducibility. The reverberation time of the room is expressed by the arithmetic mean derived from the total number of all reverberation time measurements in each frequency band.

The equivalent sound absorption area of the test specimen A_T is calculated as the difference between the equivalent sound absorption area of the reverberation room with test specimen A_2 and the equivalent sound absorption area of the empty reverberation room A_1 without test specimen.

The equivalent sound absorption coefficient α_s describes the ratio of the equivalent sound absorption area A_T of a test specimen divided by the area of the test specimen.

The evaluated sound absorption coefficient α_w is a single-number frequency-independent value which equals the value of the reference curve at 500 Hz after shifting it.

6 Note

The results are based on measurements performed under laboratory conditions with artificial excitation (standard procedure). The test results are applicable in due consideration of the national provisions and the local circumstances and/or constructions.

Measurement of sound absorption coefficient in a reverberation room

Annex SA – Sound Absorption

Page 1 of 2

TFI sample number: 2100195 Testing period: 17.02.2021
 Product designation: [REDACTED] Installation: 17.02.2021
 Installed by: TFI Aachen GmbH
 Mounting type: E-200, tested on a frame closed at the side with a distance of 20 cm to the surface of the room.
 (ISO 354 Annex B)
 Remarks: 18 pleats per meter

Object set-up:
 (if multi-parted;
 from top to bottom)

Reverberation room without sample:


Relative humidity: 51,8 %
 Temperature: 18,4 °C
 Barometric pressure: 100,0 kPa

Reverberation room with sample:

Relative humidity: 51,8 %
 Temperature: 18,4 °C
 Barometric pressure: 100,0 kPa

Surface area: 10,80 m²
 Room volume: 222,30 m³
 Total room area S_t : 223,60 m²

Frequency f [Hz]	α_p Oktave
100 125 160	0,15
200 250 315	0,40
400 500 630	0,60
800 1000 1250	0,45
1600 2000 2500	0,55
3150 4000 5000	0,70



Weighted sound absorption coefficient according to ISO 11654

$\alpha_w = 0,55$ (H)

Weighted sound absorption coefficient according to ISO 11654

 $\alpha_w = 0,55 \quad (H)$

 Surface area: 10,80 m²

 Room volume: 222,30 m³

 Total room area S_t : 223,60 m²

Frequency [Hz]	α_p	α_s		T1 [s]	T2 [s]
50		0,05		9,86	8,64
63	0,05	-0,01		12,64	13,14
80		0,05		13,62	11,46
100		0,11		13,68	9,31
125	0,15	0,10		13,75	9,78
160		0,19		14,30	7,86
200		0,33		14,65	5,94
250	0,40	0,41		14,61	5,25
315		0,45		14,05	4,86
400		0,60		12,80	3,89
500	0,60	0,66		12,09	3,57
630		0,61		11,79	3,72
800		0,47		10,77	4,27
1000	0,45	0,39		9,36	4,46
1250		0,50		8,21	3,67
1600		0,54		7,23	3,31
2000	0,55	0,53		6,05	3,08
2500		0,63		5,15	2,61
3150		0,67		4,19	2,27
4000	0,70	0,70		3,37	1,98
5000		0,79		2,58	1,60

Reverberation room without sample:

Relative humidity: 51,8 %

Temperature: 18,4 °C

Barometric pressure: 100,0 kPa

Reverberation room with sample:

Relative humidity: 51,8 %

Temperature: 18,4 °C

Barometric pressure: 100,0 kPa

Remarks:

18 pleats per meter